

Mounting clamp, 4 mounting locations

Powering Business Worldwide*

Part no. M22-A4
Article no. 279437
Catalog No. M22-A40

	r programme	

Product range	RMQ-Titan (drilling dimensions 22.5 mm)
Basic function	Accessories Fixing adapters
Basic function accessories	Mounting adapter
Subrange	Accessories RMQ
Accessories	Fixing adapters
Single unit/Complete unit	Single unit
Function	Mounting clamp (front mounting) for 4-contact LED elements
Fixing	Front fixing
For use with	Contact elements M22-(C)K M22-WR4, -D4, -WJ, -WRJ
Configuration	1 4 2 3
Degree of Protection	IP20
Connection to SmartWire-DT	no

Approvals

• •			
Product Standards	IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CSA-C22.2 No. 94-91; CE marking		
UL File No.	E29184		
UL Category Control No.	NKCR		
CSA File No.	012528		
CSA Class No.	3211-03		
North America Certification	UL listed, CSA certified		

General

20110141			
Standards			IEC/EN 60947 VDE 0660
Lifespan, mechanical	Operations	x 10 ⁶	>5
Operating frequency	Operations/h		≤ ₃₆₀₀
Operating torque (screw terminals)		Nm	≦ _{0.8}
Degree of Protection			IP20
Climatic proofing			Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30
Ambient temperature		°C	
Open		°C	- 25 - + 70
Mounting position			As required
Terminal capacities		mm^2	
Solid		mm^2	0.75 - 2.5
Stranded		mm^2	0.5 - 2.5

Contacts

ontacts .				
Rated impulse withstand voltage	U_{imp}	V AC	6000	
Rated insulation voltage	U_{i}	V	500	
Overvoltage category/pollution degree			III/3	
Control circuit reliability				
at 24 V DC/5 mA	HF	Fault probabilit	$< 10^{-7}, < 1$ fault in 10^7 operations by	
at 5 V DC/1 mA	H _F	Fault probabilit	$< 5 \times 10^{-6}$, < 1 failure in 5×10^{6} operations by	
Max. short-circuit protective device				
Fuseless		Туре	PKZM0-10/FAZ-B6/1	

l _e	A	
I _e	^	
I _e	۸	
	А	6
I _e	Α	6
l _e	Α	4
I _e	Α	2
l _e	Α	3
I _e	Α	1.7
I _e	Α	1.2
I _e	Α	0.8
I _e	Α	0.3
Operations	x 10 ⁶	1.6
Operations	x 10 ⁶	1
Operations	x 10 ⁶	0.7
Operations	x 10 ⁶	1.2
	I _e I _e I _e I _e I _e Operations Operations Operations	I _e A Operations x 10 ⁶ Operations x 10 ⁶ Operations x 10 ⁶

Data for design verification according to IEC/EN 61439			
Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	0
Heat dissipation per pole, current-dependent	P _{vid}	W	0
Equipment heat dissipation, current-dependent	P _{vid}	W	0
Static heat dissipation, non-current-dependent	P _{vs}	W	0
Heat dissipation capacity	P _{diss}	W	0
EC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $$			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Please enquire
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			Not applicable.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.


Technical data ETIM 5.0


Low-voltage industrial components (EG000017) / Adapter for control circuit devices (EC001020)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Adapter for command devices (ecl@ss8-27-37-12-26 [AKF044010])

Built-in diameter	mm	22
Number of appliances to build in		4

Dimensions





mounting clamp Fixing adapter (front mount) for 4

Additional product information (links)

IL04716002Z (AWA1160-1745) RMQ-Titan System

IL04716002Z (AWA1160-1745) RMQ-Titan System

 $ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL04716002Z2013_08.pdf$